



Note: For inline meters, double Ax will be used, first Ax is

for the input cords, and the 2nd Ax is for the output cords

Values None: Default (3 Meter) A0=0 Meter (Inlet only, no power cord) A18-0.5 Meter A13=0.6 Meter (2ft) A7=1 Meter A7=1 Meter A1=1.5 Meter A1=1.5 Meter A2=2 Meter A2=2.5 Meter A14=2.6 Meter A3=3 Meter A3=3.5 Meter A5=3.5 Meter A5=4.5 Meter A6=5 Meter A15=5.5 Meter A12=6 Meter A11=6 Meter A11=6 Meter A11=6 Meter A11=10 Meter A17=10 Meter NUTES: 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES. 2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION. 3. UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE IN MILLITERS [INCHES]. 4. MOUNTING BUTTON IS AN ALTERNATIVE MOUNTING METHOD TO THE TOOLESS MOUNT FOR 3RD PARTY ENCLOSURE. BUTTON IS PROVIDED WITH THE UNIT. DETAILED INSTALLATION INSTRUCTIONS CAN BE FOUND IN THE PROVIDED MANUAL. 5. BRACKET KITS TO MOUNT TO SPECIFIC 3RD PARTY ENCLOSURES ARE AVAILABLE AS OPTIONS. 6. LENGTH OF THE CORD IS 3000MH-/-70MM 7. DIMENSION TOLERANCE: LENGTH /-3MM, WIDTH -/-1MM, DEPTH -/-0.5MM 8. REFER TO THE TABLE FOR DETAIL CORD LENGTH DEFINITION

A brand of 🖾 legrand EVA LIN Feb. 23,2017 Drawing Maker: Sam_L Feb. 23,2017 esign Engineer: Tom_H Feb. 23,2017 Approver

PROJECTION THIRD ANGLE THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF RARITAN, INC. AND SHALL NOT BE COPIED, REPRODUCED OR USED, IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM RARITAN, INC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

DO NOT SCALE DRAWING iPDU Zero U Single Phase, 16A/200-240V SHEET 1 OF 1 InputType: IEC60320 C20 Plug Type: IEC60309 16A OutputType: C13 (12)

> PX3-5260V & PX3-4260V PX3-5260V-M5 & PX3-4260V-M5 2A