


- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- I. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
  2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.
  3. UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE IN MILLITERS INVENTS.
  4. MOUNTING BUTTON IS AN ALTERNATIVE MOUNTING METHOOT OT HE TOOLESS MOUNT FOR 3RD PARTY ENCLOSURE BUTTON IS PROVIDED WITH THE UNIT. DETAILED INSTALLATION INSTRUCTIONS CAN BE FOUND IN THE PROVIDED MANUAL.
  5. BRACKET KITS TO MOUNT TO SPECIFIC 3RD PARTY ENCLOSURES ARE AVAILABLE AS OPTIONS.
  6. LENGTH OF THE CORD IS 3000MH-7-70MM
  7. DIMENSION TOLERANCE: LENGTH +/-3MM, WIDTH +/-1MM, DEPTH +/-0.5MM



## A brand of Lilegrand

Drawing Maker:	Eva Lin	May 28, 2018
Design Engineer:	Sam_L	May 28, 2018
Approver:	Tom_H	May 28, 2018



PROPERTY OF RARITAN, Inc. AND SHALL NOT BE COPIED, REPRODUCED OR USED, IN WHOLE OR IN

AVAILABLE INFORMATION AND IS SUBJECT TO

CHANGE WITHOUT NOTICE.

PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM RARITAN, Inc. THIS DRAWING IS BASED UPON LATEST

DO NOT SCALE DRAWING SHEET 1 OF 1

TITLE: iPDU Zero U Three Phase, 24A/360-415V Plug Type: IEC60309 32A 3PY (UL) THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE Outlet Type: C13 (36), C19 (12)

MPX3-1085I2U-V2 M5

MODEL NO.

PX3-1085I2U-V2 &PX3-1085I2U-V2M5

REV. 2A